

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR
CAMERON WATER, WV3302603
V#2022-391010

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 09/01/2021 and 09/30/2021, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period:
3A, MONITORING, ROUTINE, MAJOR (RTCR)	09/01/2021 to 09/30/2021
Valid Compliance Total Coliform Sample(s) Not Received	

What happened? What is being done? (Describe corrective action)

Samples were taken on time but when lab received the samples there was a damaged sample bottle. Operator needed to resample and have those sent back to lab. By the time samples were received by the lab it was not within compliance period. Operator is going to start taking samples earlier in the month to make sure enough time for delivery and to be received by lab for instances that something happens like this again during shipping. Samples let were received after compliance period did pass.

Public Notice being distributed to residents of The City of Cameron.

For more information, please contact
Nichole M. Bryan at 304-686-2366 or 44 Main Street Cameron, WV 26033

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by CAMERON WATER
State Water System ID# WV3302603

Date Distributed October 20th, 2022